



Certificate of Completion

Duct Sealing Performed For:

Coursen, Matthew
5411 Newington Rd
Bethesda, MD 20816

Overall Sealing Results

When we arrived,
YOUR DUCTS HAD:

158.6 CFM of Leakage, equivalent to a
30.0 Square Inch Hole


This equals 95.2 refrigerators full of air loss every hour.

After we finished,
YOUR DUCTS HAVE:

11.3 CFM of Leakage, equivalent to a
2.1 Square Inch Hole

This corresponds to a **92.9% Reduction in Duct Leakage.**

Note: Duct Leakage results are calculated in Cubic Feet per Minute (CFM) measured at a standard OPERATING PRESSURE of 25 Pa.



Aeroseal Technician **Brian**

Aeroseal Case ID **4174**

Date of Seal **8/18/2017**

System Description **forced air**

Seal Description **whole home**

Hardware **HomeSeal**

AEROSEAL[®]
Duct Sealing From The Inside

Duct Sealing Performed By:

James A. Wheat & Sons, Inc.
7834 Beechcraft Ave.
Gaithersburg, MD 20879
Phone: 301-670-1944