



Certificate of Completion

Duct Sealing Performed For:

kessler, mark and anna
4819 alton place nw
washington, dc 20008

Overall Sealing Results

When we arrived,
YOUR DUCTS HAD:

323.6 CFM of Leakage, equivalent to a
61.1 Square Inch Hole


This equals 194.2 refrigerators full of air loss every hour.

After we finished,
YOUR DUCTS HAVE:

62.6 CFM of Leakage, equivalent to a
11.8 Square Inch Hole

This corresponds to a **80.7% Reduction in Duct Leakage.**

Note: Duct Leakage results are calculated in Cubic Feet per Minute (CFM) measured at a standard OPERATING PRESSURE of 25 Pa.



Aeroseal Technician **stockman**

Aeroseal Case ID **4174**

Date of Seal **10/13/2017**

System Description **whole house**

Seal Description **whole house**

Hardware **HomeSeal**

AEROSEAL[®]
Duct Sealing From The Inside

Duct Sealing Performed By:

James A. Wheat & Sons, Inc.
7834 Beechcraft Ave.
Gaithersburg, MD 20879
Phone: 301-670-1944